

AGRI-ANALYSE ENR.
1730 WELLINGTON SOUTH
SHERBROOKE, QC, J1M 1K9
TEL: (819) 821-2152 FAX: (819) 348-1888
TOLL FREE: 1-800 567- 6045



WATER ANALYSIS REPORT

Sample Number : 130219050
Description : H2O
Identification :
Date Printed : 3/14/2013

Client Name : AGRI-ANALYSE ENR.
1730 WELLINGTON
SHERBROOKE, QC. J1M 1K9

Telephone: (819) 821-2152
Fax : (819) 348-1888
Rep :
E-mail:

Analyse :

MAXIMUM ACCEPTABLE LIMITS

BHAA :	0	Maximum acceptable 500 CFU / 100 mL
Total Coliforms CFU/100 mL :	0	Maximum acceptable 10 CFU / 100 mL
Non Colony Coliforms CFU/Membrane :	0	Maximum acceptable 200 CFU / Membrane
E-Coli :	0	Maximum acceptable 0 CFU/ 100 mL

TNI = TOO NUMEROUS TO BE IDENTIFIED

The results shown are within acceptable limits. Your water is SAFE TO DRINK

Mitar Mojovic, Chemist

